

IMPORTANT INSTRUCTIONS

For Installation LS452



LUMASCAPE USA INC
1300 Industrial Rd, Unit #19
San Carlos, CA 94070, USA
T 1-(650)-595-LUMA(5862)
F 1-(650)-595-5820
E info@lumascope.com
W www.lumascope.com Free Call 1-866-695-LUMA(5862)

1 CAUTION

DO NOT OVERTIGHTEN **NO DOWNWARD FORCE**

NO POWER TOOLS **DO NOT CUT or SHORTEN**

Do not shorten, interfere or disconnect cable from fitting. Warranty will be void if cable assembly is tampered with.

2A

LS452

130mm (5.12") MIN

Ø172mm (6.77")

Ensure free draining soil

90°C min rated hookup wiring (supplied)

OR

2B

LS452 + LS647-KUL

Ø179mm (7.05")

254mm (10.0") MIN

3

3 Nm

4

5

LS6069

LS6067

LS6065 or LS6066

LS6064

6

7

3 Nm

8

4 Nm

2 Nm